

GLV 044.01

Growatt

S, MTL-S

C10/26 - DECLARATION OF CONFORMITY for power-generating units

GLV ed2.1.2 (12/2019)

for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)



The undersigned,

Manufacturer:

Address:

Shenzhen Growatt New Energy Technology Co.
No. 28 Guangming Road, Longteng community,
Shiyan, Baoan, Shenzhen, P. R. China

Represented by:

Country:

email:

Telephone:

Vivian
China
zhen.zou@ginverter.com
(86)13554702086

the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
 - 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
 - 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available * in the technical file:
 - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
 - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

Done :Shenzhen

(location)

On: 26th, Dec, 2019

(date)


(stamp manufacturer & signature)



Homologated by Synergrid on:

Stamp Synergrid & signature:

25/02/2020



*** Transition period till 01/05/2020** (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):

If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a **temporary homologation** may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case, the temporary C10/26 homologation will be withdrawn.

| | | |
|----|---|---|
| 11 | Additional characteristics | In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. Notes: Only units < 1 MW that are "type B ready" may be applied in an installation \geq 1 MW (installation "type B" according to the European Network Code (ECN), A unit < 1 MW is only "type B ready" if it complies with all optional properties listed in column I of the checklist annex D. These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation. |
| 12 | Limitations | Indicate the applications for which the unit is suitable. Include an "X" with each application for which the unit can be used. |
| 13 | Application | Date on which the submitted homologation file was approved by Synergrid for a limited period of time. A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2). The expiry date for a temporary homologation is 01/05/2020 see conditions in chapter 3 of C10/11 ed.2.1 (01/09/2019). |
| 15 | Synergrid approval date Final homologation | Date on which the submitted homologation file was definitively approved by Synergrid. A final approval will be granted as soon as Synergrid has a fully compliant homologation dossier. A final homologation only remains valid under the following conditions: No changes that have an influence on the initial approval are made to (the production of) the units. There is no new edition of prescription C10/11. The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure SI/01 for homologation of material, which is applicable. (1) |

(1) - SI/01 Technical specifications: procedure for application for homologation and removal of homologation of materials

i.v.

SYNERGRID s.b.l.-v.z.w.
 Galerie Bavensteingalerij 4/2
 BE-1000 Bruxelles/Brussel
 T.V.A./B.T.W : BE 0402.958.091